



TIE-IN SCHEDULE

1	4" 900# RF GAS INLET EL. 7'-3" ±	5	3" 150# RF FLARE HEADER EL. 9'-0" ±	9	1" 3000# NPT FUEL GAS SUPPLY EL. 9'-0" ±
2	4" 900# RF GAS OUTLET EL. 1'-0" ±	6	1 1/2" 150# RF VENT HEADER EL. 9'-0" ±	10	3/8" 3000# NPT HP INSTRUMENT GAS VENT EL. 8'-4" ±
3	1" 600# RF HC OUTLET EL. 2'-0" ±	7	2" MNPT FLOOR DRAIN EL. -0'-5 1/4" ±	11	2" 150# RF DRAIN HEADER EL. 0'-6" ±
4	1" 3000# NPT FUEL GAS INLET EL. 3'-0" ±	8	4" 900# RF RECYCLE LINE EL. 2'-6" ±	12	2" MNPT VENT BY OTHERS EL. 13'-5" ±

NO.	REVISION	BY	CHKD.	DATE
3	AS BUILT	KMS		04/11/29
2	TAG #3 WAS 1" NPT	D.S.		04/08/25
1	GENERAL REVISIONS	KMS		04/08/23
0	ISSUED FOR CONSTRUCTION	CM		04/07/28
A	ISSUED FOR APPROVAL	CM		04/07/20

CUSTOMER REFERENCE	AB0200-003
Presson ENERFLEX	

NOTES:

- 1) ALL ELEVATIONS ARE TAKEN FROM TOP OF CHECKER PL REF ELEV 0'-0".
- 2) FOR PIPING SURFACE PREP AND PAINT NOTES SEE INSTRUMENT LIST.
- 3) SHOP SUPPORT ALL PIPING AS REQUIRED
- 4) ALL PIPING UNDER 2" NPS, SHOWN FOR REFERENCE ONLY
- 5) TOTAL APPROX PACKAGE WEIGHT: - 46,000 lbs (21,000 kg).

CUSTOMER:					JOB NO.	
PROJECT: GLYCOL DEHYDRATION UNIT GENERAL ARRANGEMENT						
TITLE:						
DRAWN CM	CHECKED	APPROVED	SCALE 3/4"=1'-0"	DATE 04/07/20	DRAWING NUMBER	